Building Description	Sample Date	Sample Time (12 HR Clock)	Collected By	Sample ID Number	Sample Location Description	Fixture Type	Date of Last Use	Time of Last Use (12 HR Clock)	Sample Type	Sample Volume (mL)	Laboratory Name	Analytical Method	Concentration (ug/L)	Reporting Limit (ug/L)	Notes
	12/2/17	10:15 AM	Eric Colombo		1 Kitchen IM		12/1/2017	10:30 PM		250	TEKLAB	EPA 200.8	21.3	1.00	
	12/2/17	10:16 AM	Eric Colombo		1A Kitchen IM-Flush		12/1/2017	10:30 PM		250	TEKLAB	EPA 200.8	13.1	1.00	
	12/2/17	10:23 AM	Eric Colombo		2 Serving Line KS Prep Sink Rt.		12/1/2017	10:30 PM		250	TEKLAB	EPA 200.8	62.8	1.00	
	12/2/17	10:24 AM	Eric Colombo		2A Serving Line KS Prep Sink Right-Flush		12/1/2017	10:30 PM		250	TEKLAB	EPA 200.8	9.1	1.00	
	12/2/17	10:27 AM	Eric Colombo		3 Water Fountain DF by Office Right Back to Office		12/1/2017	10:30 PM		250	TEKLAB	EPA 200.8	22.4	1.00	
	12/2/17	10:28 AM	Eric Colombo		3A Water Fountain DF by Office Right Back Flush		12/1/2017	10:30 PM		250	TEKLAB	EPA 200.8	1.0	1.00	