ISBE ID	Building ID	Building Description	Sample Date	Sample Time (12 HR Clock)	Collected By	Sample ID Number	Sample Location Description	Fixture Type	Date of Last Use	Time of Last Use (12 HR Clock)	Sample Type	Sample Volume (mL)	Laboratory Name	Analytical Method	Concentration (ug/L)	Reporting Limit (ug/L)	Notes
			12/2/17	9:35 AM	Eric Colombo		1 Kitchen IM		12/1/2017	11:00 PM		250	TEKLAB	EPA 200.8	36.1	1.00	
			12/2/17	9:37 AM	Eric Colombo		1A Kitchen IM Flush		12/1/2017	11:00 PM		250	TEKLAB	EPA 200.8	48.6	1.00	
			12/2/17	9:50 AM	Eric Colombo		2 Rm 82 Kindergarten Sink-S		12/1/2017	11:00 PM		250	TEKLAB	EPA 200.8	5.3	1.00	
			12/2/17	9:51 AM	Eric Colombo		2A Rm 82 Kindergarten Sink-S-Flush		12/1/2017	11:00 PM		250	TEKLAB	EPA 200.8	1.5	1.00	
			12/2/17	9:55 AM	Eric Colombo		3 Sink-S-by Rm 18		12/1/2017	11:00 PM		250	TEKLAB	EPA 200.8	< 1.0	1.00	
			12/2/17	9:56 AM	Eric Colombo		3A Sink-S-by Rm 18-Flush		12/1/2017	11:00 PM		250	TEKLAB	EPA 200.8	2.7	1.00	